

## FLUID OUNCES OF CAPTOR PER THOUSAND GALLONS OF WATER

pH	Parts per Million Chlorine (1-10)									
	1	2	3	4	5	6	7	8	9	10
<b>6.5</b>	0.69	1.39	2.08	2.78	3.47	4.16	4.86	5.55	6.25	6.94
<b>6.8</b>	0.67	1.34	2.02	2.69	3.36	4.03	4.70	5.38	6.05	6.72
<b>7.0</b>	0.66	1.32	1.97	2.63	3.29	3.95	4.61	5.26	5.92	6.58
<b>7.2</b>	0.64	1.29	1.93	2.57	3.21	3.86	4.50	5.14	5.78	6.43
<b>7.4</b>	0.63	1.26	1.89	2.51	3.14	3.77	4.40	5.03	5.66	6.28
<b>7.6</b>	0.61	1.23	1.84	2.45	3.07	3.68	4.29	4.90	5.52	6.13
<b>7.8</b>	0.60	1.20	1.79	2.39	3.00	3.59	4.18	4.78	5.38	5.98
<b>8.0</b>	0.58	1.17	1.75	2.33	2.92	3.50	4.09	4.67	5.25	5.84
<b>8.5</b>	0.55	1.09	1.64	2.19	2.73	3.28	3.83	4.37	4.92	5.47
<b>9.0</b>	0.51	1.02	1.53	2.04	2.54	3.06	3.57	4.08	4.58	5.09
<b>9.5</b>	0.47	0.94	1.42	1.89	2.36	2.83	3.31	3.78	4.25	4.72
<b>10.0</b>	0.44	0.87	1.31	1.74	2.18	2.61	3.05	3.48	3.92	4.35

\*Measure pH at actual DeChlorination Point

These calculations are approximate and based on theoretical values.  
 Variations at specific sites include water quality and the use of other chemicals.  
 Other factor may also increase to decrease actual feed requirements.  
 All dosing decisions should be closely monitored as to their influence on overall water quality.

## GALLONS OF CAPTOR PER MILLION GALLONS OF WATER

	<b>Parts Per Million Chlorine (1-10)</b>									
	1	2	3	4	5	6	7	8	9	10
<b>pH</b>										
<b>6.5</b>	5.4	10.9	16.3	21.7	27.1	32.5	37.9	43.4	48.8	54.2
<b>6.8</b>	5.3	10.5	15.8	21.0	26.3	31.5	36.8	42.0	47.1	52.5
<b>7.0</b>	5.1	10.3	15.4	20.6	25.7	30.8	36.0	41.1	46.2	51.4
<b>7.2</b>	5.0	10.0	15.1	20.1	25.1	30.1	35.2	40.2	45.2	50.2
<b>7.4</b>	4.9	9.8	14.7	19.6	24.5	29.4	34.3	39.2	44.2	49.1
<b>7.6</b>	4.8	9.6	14.4	19.2	24.0	28.7	33.5	38.3	43.1	47.9
<b>7.8</b>	4.7	9.3	14.0	18.7	23.4	28.0	32.7	37.4	42.1	46.7
<b>8.0</b>	4.6	9.1	13.7	18.2	22.8	27.3	31.9	36.5	41.0	45.6
<b>8.5</b>	4.3	8.4	12.8	17.1	21.3	25.6	29.9	34.1	38.4	42.7
<b>9.0</b>	4.0	8.0	11.9	15.9	19.9	23.9	27.8	31.8	35.8	39.8
<b>9.5</b>	3.7	7.4	11.1	14.8	18.4	22.1	25.8	29.5	33.2	36.9
<b>10.0</b>	3.4	6.8	10.2	13.6	17.0	20.4	23.8	27.2	30.6	34.0

\*Measure pH at actual DeChlorination Point

These calculations are approximate and based on theoretical values.

Variations at specific sites include water quality and the use of other chemicals.

Other factor may also increase to decrease actual feed requirements.

All dosing decisions should be closely monitored as to their influence on overall water quality.